

## **Certificate of Flame Resistance**

Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and offices also in Sun Valley, California, and in Orlando, Florida.

This FR fabric described below has been treated with a flame retardant chemical such that the fabric meets the minimum requirements of flame resistance established by the following tests:

NFPA 701-2010, TM #1

Calif. Title 19, test # 1237.1, small scale

The material listed below was treated with a fire retardant chemical approved by and registered with the California State Fire Marshall. This chemical is approved for use on the material listed below:

CSFM Approval No.: F-053.01



The flame retardancy has a minimum lifetime of at least one (1) year, but is likely to be effective for much longer. The flame retardancy will withstand up to three (3) dry cleanings or non-water washing processes. The flame retardant chemical **WILL** be removed by water washing. Wide fluctuations in atmospheric humidity as well as accumulations of airborne dust and oils will diminish the endurance and effectiveness of the flame retardant chemical.

Rose Brand recommends annual testing of this fabric using NFPA 705, Field Test Method for Textiles.

Owner/Purchaser Name: To Be Determined

Purchaser PO#: T.B.D.

Purchaser Project/Event Name: T.B.D.

Rose Brand Order: T.B.D. Sales Order Date: T.B.D.

Fabric Used: Spinnaker 122 in FR

For Rose Brand Textile Fabrics Customer Service Representative Special New York City Certificate Available Upon Request