

800-360-5056 818-505-6290 Fax: 818-505-6293

Certificate of Flame Resistance

Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey and offices also in Sun Valley, California.

The fabric or substrate described below meets the minimum requirements of flame resistance established by the following tests:

•NFPA 701-2010, TM #1 •Calif. Title 19, test # 1237.1, small scale •British BS 5867: Part 2:1980

800-223-1624 201-809-1730 Fax: 201-809-1851



The material listed below is approved for use by the California State Fire Marshall. CSFM Approval No.: F-663.01

Made with non-combustible elements, this **IFR** fabric is inherently and permanently flame resistant for the life of the fabric, without the addition of flame retardant chemicals. This flame resistance will **NOT** wash out.Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 Field Test method for textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric.

Owner/Purchaser Name: To Be Determined Purchaser PO#: TBD Purchaser Project/Event Name: Rose Brand Order: TBD Sales Order Date: TBD

Fabric Used: XX Yards 52 in. IFR Crushed Trevira Silk

For Rose Brand Textile Fabrics Customer Service Representative Special New York City Certificate Available Upon Request