



CERTIFICATE OF FLAME RESISTANCE

Rose Brand is in business in New York, New York, with headquarters in Secaucus, New Jersey and offices also in California.

The IFR (Inherently Flame Retardant) fabric described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701 (1999 ed.), test method #1
- NFPA 705 (1997 or later) Field Test Method for Textiles
- California Administrative Code Title 19, Paragraph 1237, small scale
- ASTM E-84 (a/k/a NFPA 255, UL 723, or UBC 8-1); this fabric is rated Class A (Class 1) for flame spread and smoke generation for interior wall & ceiling finish



This fabric is woven with a *non-combustible* filament that the Fire Marshal of the State of California has registered as **F-23202**. The fabric is inherently and permanently flame resistant for the life of the fabric. This flame resistance will NOT wash out. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 (1997 or later) Field Test Method for Textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric. Cold water washing with gentle detergent followed by air drying will restore any lost flame retardance.

Purchaser's Name:

Rose Brand Order #:

Dated:

Fabric used: 48" wide, 100% Modacrylic Polyester, Banjo Cloth

Complete and signed certificate is issued at invoicing upon request.