

Received:05/07/2007 Completed:05/11/2007 Letter: A2 rb P.O.#: Test Report #: 2-67624-2-

Client's Identification Avora Lining, Black. 100% VISA Intrinsic Polyester. 54" Wide

Tested For: **Bob Bertrand, Gen. Mgr.** Key Test: NFPA 701-89 Sm 95
 Rose Brand
 4 Emerson Lane Tel: 1-(212)-242-7554 Ext: 115
 Secaucus, NJ 07094 Fax: 1-(212)-242-7565

PC: 1H

TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Resistant Textiles and Films 1989 Edition (Small Scale Procedure for Curtains & Draperies Weighing Less than 10 oz/yd²)

Note: NFPA 701 - 1989 Edition has been superseded by NFPA 701 - 1996 Edition. However, the 1989 Edition still remains in effect in that some of the older building codes call for testing by the 1989 Edition.

RESULTS REPORTED: Initially
 After 3 dry cleanings
 After 5 launderings @ 160°F

RESULTS:

	Specimen #	Afterflame* (seconds)	Flaming Drip (seconds)	Char Length (inches)
Length:	1	8.0	0.0	4.2
	2	7.0	0.0	5.6
	3	0.0	0.0	3.7
	4	1.7	2.0	4.3
	5	6.5	0.0	4.8
Width:	6	5.8	0.0	5.5
	7	5.8	0.0	6.1
	8	5.9	0.0	6.8
	9	0.0	0.0	5.4
	10	0.0	0.0	4.9
		Avg: 0.2	Avg: 5.1	

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 5.2 oz/yd²

REMARKS: None.

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

Complies; Does not comply; Requires testing of 5 additional specimens

Received:05/07/2007	Completed:05/11/2007	Letter: A2	rb	P.O.#:	Test Report #:	2-67624-2-
Client's Identification	Avora Lining, Black. 100% VISA Intrinsic Polyester. 54" Wide					
Tested For: Bob Bertrand, Gen. Mgr.	Key Test: NFPA 701-89 Sm				95	
Rose Brand	Tel: 1-(212)-242-7554				Ext: 115	
4 Emerson Lane	Fax: 1-(212)-242-7565					
Secaucus, NJ 07094						

ACCEPTANCE CRITERIA:


Afterflame (seconds)	Flaming Drip (seconds) Maximum Average	Char Length (inches)	
		Max.Avg.	Max.Ind.Spec.
*	2.0	6.5"	7.5"

* Afterflame is required to be recorded;
however, it is not factored into the Acceptance Criteria.

RETEST PROVISION:

Test 5 additional specimens if only 1 specimen exceeds 7.5" Char Length.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 701 1989 Edition Small Scale Procedure for Curtains and Draperies.



AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /rb

(Page 2 of 2)