

96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com

Page 1

Received:07/1	5/2008 Completed: 07/16/2008	Letter: W	rb	P.O.#: 0000043820	Test Report #:	2-744	86-0-
Client's Identification	Avora Lining Plus. 126" wide.	100% Visa A	vora P	olyester. Used for Stage	Draperies		
l .	Bob Bertrand/Yesenia Varga Rose Brand	s		Key Test: Ni	FPA 701-89 Sm		105
4 Emerson Lane Secaucus, NJ 07094			Tel: 1-(800)-223-1624 Ext: 115 Fax: 1-(201)-809-1851				

PC: 1H

TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Resistant Textiles and Films 1989 Edition (Small Scale Procedure for Curtains & Draperies Weighing Less than 10 oz/yd²)

Note: NFPA 701 - 1989 Edition was specified by the older building codes for draperies, window treatments, and similar hanging decorations. The older building codes required both the Small Scale and Large Scale Tests.

In 1996 NFPA 701 was revised and an entirely different test was developed for draperies, window treatments, and similar hanging decorations. This single test (which replaces the 1989 Tests) is designated as Test Method 1.

RESULTS REPORTED: [x] Initially

[ ] After 3 dry cleanings

[ ] After 5 launderings @ 160°F

RESULTS:	Specimen #	Afterflame* (seconds)	Flaming Drip (seconds)	Char Length (inches)
Length:	1	0.0	0.0	5.1
10119 0111	2	0.0	0.0	4.1
	3	30.0+	0.0	(10.0)
	4	0.0	0.0	4.5
	5	0.0	0.1	4.0
Width:	6	5.9	0.5	5.6
	7	6.7	0.9	5.2
	8	22.8	0.6	5.5
	9	10.9	0.8	5.0
	10	6.4	11.0	5.6
			Ava: 1.4	Ava: 5.5

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 7.1 oz/yd²

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

[ ] Complies; [ ] Does not comply; [x] Requires testing of 5 additional specimens



96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com

Page 2

Received:07	/15/2008 C	ompleted:07/16/2008	Letter: W	rb	P.O.#: 0000043820	Test Report #:	2-74486-0-
Client's Identificati	1	ining Plus. 126" wide.	100% Visa Av	ora Po	olyester. Used for Stage	Draperies	
Tested For:	Bob Ber	trand/Yesenia Varga	s		Key Test: N	FPA 701-89 Sm	10:
	Rose Brar 4 Emerson Secaucus,					(800)-223-1624 (201)-809-1851	Ext: 115

ACCEPTANCE CRITERIA:

Afterflame (seconds) \_\_\_\_\_

Flaming Drip (seconds)

Maximum Average \_\_\_\_\_\_ 2.0

Char Length (inches)

Max.Avg. Max.Ind.Spec. 6.5" 7.5"

\* Afterflame is required to be recorded; however, it is not factored into the Acceptance Criteria.

RETEST PROVISION:

Test 5 additional specimens if only 1 specimen exceeds 7.5" Char Length.

REMARKS: None.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 701 - 1989 Edition Small Scale Procedure for Curtains and Draperies.

AUTHORIZED SIGNATURE

THE GOVMARK ORGANIZATION, INC. /jb

Heatteer E. Robertso

MS. HEATHER ROBERTSON

(Page 2 of 2)