



**Rose Brand East**

4 Emerson Lane, Secaucus, NJ 07094  
800-223-1624 201-809-1730 Fax: 201-309-1851

**Rose Brand West** CA Lic. #1024256

11440 Sheldon Street, Sun Valley, CA 91352  
800-360-5056 818-505-6290 Fax: 818-505-6293

## Certificate of Flame Resistance

Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and offices also in Sun Valley, California, and in Orlando, Florida.

The fabric or substrate described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701-2010, TM #1
- Calif. Title 19, test # 1237.1, small scale
- Canada ULC S-109, small & large flame tests
- British BS 5867: Part 2:1980
- ASTM E-84 earning a Class I or A rating

The material listed below is approved for use by the California State Fire Marshall.

**CSFM Approval No.: F-705.01**



Made with non-combustible elements, this **IFR** fabric is inherently and permanently flame resistant for the life of the fabric, without the addition of flame retardant chemicals. This flame resistance will **NOT** wash out. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 Field Test method for Textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric.

**Owner/Purchaser Name:** To Be Determined

**Purchaser PO#:** T.B.D.

**Purchaser Project/Event Name:** T.B.D.

**Rose Brand Order:** T.B.D.

**Sales Order Date:** T.B.D.

**Fabric Used:** Tendo Spandex 122 in IFR

For Rose Brand Textile Fabrics  
Customer Service Representative

**Special New York City Certificate  
Available Upon Request**