



Received:06/01/2007 Completed:06/05/2007 Letter: G3 rb P.O.#: Test Report #: 2-68078-3-

Client's Identification Poly Chintz, 100% Trevira Polyester, 58" wide. End Use: Stage Draperies & Lining of Stage Draperies.

Tested For: **Bob Bertrand, Gen. Mgr.** Key Test: CA 1237 Sm 95
 Rose Brand
 4 Emerson Lane Tel: 1-(212)-242-7554 Ext: 115
 Secaucus, NJ 07094 Fax: 1-(212)-242-7565

PC: AS /jd

TEST PERFORMED: California Fire Marshal Title 19: Section 1237 Fire Resistance;
 Small Scale Test - INTERIOR MATERIALS QUALIFICATION

RESULTS REPORTED: Initially
 After 3 dry cleanings
 After 5 launderings @ 160°F

RESULTS:	Specimen #	Afterflame (seconds)	Char Length (inches)
Length:	1	0	4.3
	2	0	6.4
	3	0	4.4
Width:	4	0	4.7
	5	0	4.8
	6	0	5.6
Avg:		0	5.0

PRECONDITIONING: Standard: 1 to 1.5 hours in oven at 140°-145°F.
 Alternate for materials that distort during oven conditioning:
 24 hours at 60°-80°F and 25%-50% RH.

REMARKS: None.

ACCEPTANCE CRITERIA:

Afterflame (seconds)	Char Length (inches)
1.0 maximum average	6.0 maximum average

CONCLUSION:

The above results indicate compliance.
 The above results indicate noncompliance.



Received:06/01/2007	Completed:06/05/2007	Letter: G3	rb	P.O.#:	Test Report #:	2-68078-3-
Client's Identification	Poly Chintz, 100% Trevira Polyester, 58" wide. End Use: Stage Draperies & Lining of Stage Draperies.					
Tested For: Bob Bertrand, Gen. Mgr.	Key Test: CA 1237 Sm					95
Rose Brand	Tel: 1-(212)-242-7554					Ext: 115
4 Emerson Lane	Fax: 1-(212)-242-7565					
Secaucus, NJ 07094						

Note: In August 1993 the State Fire Marshal issued a proposed revision, which permitted a maximum average afterflame of 4.0 seconds. This proposed revision was honored by the subsequent State Fire Marshals until approximately February 2004, at which time the State Fire Marshal's office reverted to the unrevised rule of 1 second maximum average for interior fabric; and 2.0 seconds maximum average for exterior fabric.

With regard to Char Length acceptance, please refer to Govmark's document "California Title 19 Section 1237" dated August 11, 2005.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by California Fire Marshal Title 19: Section 1237 Small Scale.

Heather E. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /jdr

MS. HEATHER ROBERTSON

(Page 2 of 2)