

96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com

Page 1

Received:06/0	01/2007 Completed: 06/05/2007	Letter: G2 rl	b]	P.O.#:	Test Report #:	2-6	8078-2-
Client's Identificatior	Poly Chintz, 100% Trevira Poly	ester, 58" wide. E	End U	Use: Stage Draperies & I	Linning of Stage Drap	peries.	
Tested For: Bob Bertrand, Gen. Mgr. Rose Brand				Key Test: NF	PA 701-89 Sm		95
4 Emerson Lane Secaucus, NJ 07094				,	212)-242-7554 212)-242-7565	Ext: 115	

PC: 1H

TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Resistant Textiles and Films 1989 Edition (Small Scale Procedure for Curtains & Draperies Weighing Less than 10 oz/yd^2)

Note: NFPA 701 - 1989 Edition has been superseded by NFPA 701 - 1996 Edition. However, the 1989 Edition still remains in effect in that some of the older building codes call for testing by the 1989 Edition.

RESULTS REPORTED: [x] Initially

[] After 3 dry cleanings

[] After 5 launderings @ 160°F

RESULTS:

	Specimen #	Afterflame* (seconds)	Flaming Drip (seconds)	Char Length (inches)
		THE THE RES AND AND AND USE USE		
Length:	1	0	0	5.2
	2	0	О	4.7
	3	0	0	5.7
	4	0	0	4.7
WARREN	5	0	0	4.8
Width:	6	0	0	5.0
	7	0	0	5.9
	8	0	O	4.5
	9	0	0	5.5
	10	0	0	5.2
10000000000000000000000000000000000000		į	Avg: 0	Avg: 5.1

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 3.4 oz/yd²

REMARKS: None.

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

[x] Complies; [] Does not comply; [] Requires testing of 5 additional specimens

(Page 1 of 2)



96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8958 e-mail: info@govmark.com

Page 2

Received: 06/01/2007 | Completed: 06/05/2007 | Letter: G2 rb **P.O.**#: Test Report #: 2-68078-2-Client's Poly Chintz, 100% Trevira Polyester, 58" wide. End Use: Stage Draperies & Linning of Stage Draperies. Identification Tested For: Bob Bertrand, Gen. Mgr. Key Test: NFPA 701-89 Sm 95 Rose Brand 4 Emerson Lane **Tel:** 1-(212)-242-7554 Ext: 115 Secaucus, NJ 07094 Fax: 1-(212)-242-7565

ACCEPTANCE CRITERIA:

Afterflame Flaming Drip (sec (seconds) Maximum Average

Flaming Drip (seconds)

Maximum Average

Max.Avg. Max.Ind.Spec.

2.0

6.5"

7.5"

Char Length (inches)

* Afterflame is required to be recorded; however, it is not factored into the Acceptance Criteria.

RETEST PROVISION:

Test 5 additional specimens if only 1 specimen exceeds 7.5" Char Length.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 701 1989 Edition Small Scale Procedure for Curtains and Draperies.

AUTHORIZED SIGNATURE

THE GOVMARK ORGANIZATION, INC. /jd

MS. HEATHER ROBERTSON

Ther E. Robertson

(Page 2 of 2)