

## **Certificate of Flame Resistance**

Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and offices also in Sun Valley, California, and in Orlando, Florida.

The fabric or substrate described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701-2010, TM #1
- Calif. Title 19, test # 1237.1, small scale

The material listed below is approved for use by the California State Fire Marshall.

CSFM Approval No.: F-30801



Made with non-combustible elements, this **IFR** fabric is inherently and permanently flame resistant for the life of the fabric, without the addition of flame retardant chemicals. This flame resistance will **NOT** wash out. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 Field Test method for Textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric.

Owner/Purchaser Name: to be determined Purchaser PO#: pending Purchaser Project/Event Name: pending Rose Brand Order: pending Sales Order Date: to be determined

Fabric Used: 64 inch wide, 100% polyester (90% recycled) 22 oz ReVive

For Rose Brand Textile Fabrics Customer Service Representative

Special New York City Certificate Available Upon Request