



## AFFIDAVIT OF FLAME RETARDANCY

We, the undersigned, being duly sworn, depose and say that we are in business in New York, New York, with headquarters in Secaucus, New Jersey and offices also in California.

As an employee of Rose Brand, I have field-tested the fabrics described below. In accordance with RCNY Title 3 C19-01.b.1 and Section 27-4266 of the Administrative Code of New York City, the fabrics were field-tested using standard methods as set forth by the New York City Fire Department and the N.F.P.A. 705 (ed. 1997), Match Field Test.

The fabrics described below have passed the field test on the date indicated.

This field test does not guarantee how long these treated fabrics will remain flame-retardant. At most, the added treatment is guaranteed to be effective for one year from the time of treatment. Annual field re-testing is required and necessary re-treatment is recommended. Any washing of treated materials will wash the treatment away.

**Owner's/Purchaser's Name:**

**Location of Test:**

**Rose Brand Order/Invoice #:**

**Date of Test and Affidavit:**

**Fabric Used:** 30' wide, 100% cotton, Scenery Netting

*Complete and signed certificate is issued at invoicing upon request.*