



## CERTIFICATE OF FLAME RESISTANCE

Rose Brand is in business in New York, New York, with headquarters in Secaucus, New Jersey and offices also in California.

The IFR (Inherently Flame Retardant) fabric described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701 (1989 ed.), small scale
- NFPA 701 (2004 ed.), test method #1
- California Administrative Code Title 19, Section 1237
- BS 5867- test 2 (part B)-1980 British Standard Specifications for Fabrics for Curtains and Draperies

This flame retardance is inherent to the substrate vinyl used to make this product. It will not wash out or diminish with usage or age. Accumulations of dust and oils on the surface may adversely affect the flame retardance of this product. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 (1997 or later) Field Test Method for Textiles. Cold water washing with gentle detergent followed by air drying will restore any lost flame retardance.

**Purchaser's Name:**

**Rose Brand Order #:**

**Dated:**

**Fabric used:** xxx yards of (54",86", or 110") wide, 100% (color) vinyl, **(Twin, Rear or Front) Projection Screen**

*Complete and signed certificate is issued at invoicing upon request.*