



THE ROSE BRAND GROUP OF COMPANIES

Certificate of Flame Resistance



Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and additional offices in Sun Valley, California, and in Orlando, Florida.

The fabric or substrate described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701, TM #1
- Calif. Title 19, test # 1237.1, small scale
- ASTM E-84 Class A
- BS 5867 Part 2, Type B

Made with non-combustible elements, this **IFR** fabric is inherently and permanently flame resistant for the life of the fabric, without the addition of flame-retardant chemicals. This flame resistance will **NOT** wash out. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 Field Test method for Textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric.

Owner/Purchaser Name: TBD

Purchaser PO#: TBD

Purchaser Project/Event Name: TBD

Rose Brand Order: TBD

Sales Order Date: TBD

Fabric Used: 4 Each Blizzard Series Sprinkle IFR Tendo 3 ft 2D White

SIGNATURE PROVIDED WITH PURCHASE

For Rose Brand Textile Fabrics
Customer Service Representative

**Special New York City Certificate
Available Upon Request**