



THE ROSE BRAND GROUP OF COMPANIES

Certificate of Flame Resistance



Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and additional offices in Sun Valley, California, and in Orlando, Florida.

This FR fabric described below has been treated with a flame-retardant chemical such that the fabric meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701, TM #1
- Calif. Title 19, test # 1237.1, small scale
- DIN 4102, B1
- BS 5867 Part 2, Type B

The flame retardancy has a minimum lifetime of at least one (1) year, but is likely to be effective for much longer. The flame retardancy will withstand up to three (3) dry cleanings or non-water washing processes. The flame-retardant chemical **WILL** be removed by water washing. Wide fluctuations in atmospheric humidity as well as accumulations of airborne dust and oils will diminish the endurance and effectiveness of the flame-retardant chemical.

Rose Brand recommends annual testing of this fabric using NFPA 705, Field Test Method for Textiles.

Owner/Purchaser Name: TBD

Purchaser PO#: TBD

Purchaser Project/Event Name: TBD

Rose Brand Order: TBD

Sales Order Date: TBD

Fabric Used: 20 Yards Poly Silk 60 in IFR Hot Pink

SIGNATURE PROVIDED WITH PURCHASE

For Rose Brand Textile Fabrics
Customer Service Representative

**Special New York City Certificate
Available Upon Request**